

DEPARTMENT OF GENERAL SERVICES, PURCHASING DIVISION

Dr. Robert L. Yeager Health Center
50 Sanatorium Rd, Building A
Pomona, New York 10970
Phone: (845) 364-3820 Fax: (845) 364-3809
Email: purchasing@co.rockland.ny.us

Paul Brennan, FNIGP, NIGP-CPP, CPPO
Director of Purchasing

ADDENDUM # 1

RFP-RC-2024-006 **Access Point Installation**

The information in this addendum supersedes any contradictory information set forth in the contract documents. Acknowledge receipt of this addendum in the space provided on the signature page of the bid proposal. Failure to do so, may subject the bidder to disqualification. This addendum forms a part of the contract documents.

Question # 1: Do you require the bidder/contractor to certify each data outlet and cable shall be tested and certified for permanent link compliance with TIA Category 6 568-C requirements.

Response #1: Yes, we would need certification and tested results that each cable run works as intended based on one of 3 standards ISO 11801, EN 501732 or TIA 568. We do not require compliance with all 3 standards.

SIGNED:

Paul J. Brennan

PAUL J. BRENNAN, FNIGP, NIGP-CPP, CPPO
DIRECTOR OF PURCHASING

ADDENDUM

1/30/24