

FOR THE RECORD OR SUBMISSION TO CITY OF RICHMOND, VA, I.E.C. AND LOCAL ADOPTED OR AMENDED CODES.

UTILITY COMPANY FOR FINAL TRANSFORMER SIZE, VOLTAGE, AND CREPANCIES IN UTILITY TRANSFORMER SIZING AND/OR LOCATION TO ENGINEER FOR REVISED FAULT CURRENT CALCULATIONS AND IDENTIFICATION OF EQUIPMENT AIC RATINGS.

PLANS TO UTILITY COMPANY REPRESENTATIVE FOR FINAL REVIEW PRIOR TO WORK.

URING INSTALLATION AND REQUIREMENTS WITH UTILITY COMPANY

TECTION DESIGN IS EXCLUDED. SUBMIT DRAWINGS TO FIRE OFFICIALS FOR REVIEW AND SYSTEM DETERMINATION FOR THIS CONDITIONS. IF REQUIRED, E.C. TO SUBMIT FIRE ALARM NOTIFICATION SYSTEM DESIGN IN THE FORM OF SUPPLIER SHOP DRAWING FOR FIRE ALARM SEPARATE PERMIT.

COORDINATE DIRECTLY WITH LOW VOLTAGE CONSULTANT (TELEPHONE, BURGLAR ALARM, ETC.) FOR SPECIFIC REQUIREMENTS FOR EACH SYSTEM. ANY EMPTY RACEWAYS REQUIRED BY THESE SYSTEMS SHALL BE IDENTIFIED WITH THE CONSULTANT / SUPPLIER. ANY ADDITIONAL LINE REQUIRED AND NOT SHOWN ON THESE DRAWINGS SHALL BE COORDINATED WITH ELECTRICAL ENGINEER.

ELECTRICIAN SHALL UPSIZE ALL 120V BRANCH CIRCUITS EXCEEDING 75 FEET LENGTH TO #10, CU TO ACCOMMODATE VOLTAGE DROP.

- 4-PLEX RECEPTACLE MIN. STD. WALL HEIGHT
- SPECIAL PURPOSE RECEPTACLE
- TELECOMM / DATA OUTLET W/ 3/4" C. STUB-UP (CONDUIT, BOX AND MUDRING BY E.C.)
- T.V. COAX OUTLET PRE-WIRED BY SERVICE PROVIDER
- MOTOR
- DISCONNECT-RATED FOR USE
- WEATHERPROOF
- GROUND FAULT INTERRUPTER, PROTECT DOWNSTREAM
- AC ABOVE COUNTER
- MOUNT RECEPTACLE HORIZONTALLY.

