



MAIN DISCONNECT FOR SOUTH ELECTRICAL SERVICE METERSTACK "MS-D". PROVIDE PERMANENT LAGGING INDICATING SERVICE DISCONNECT 2 OF 2 AND LOCATION OF METERSTACK IN WHICH IT FEEDS. RE: ONE LINE AND SHEET E1.0C.

[illegible]

dcb construction company, inc.
300 East 14th Avenue • Denver, Colorado 80218 • 303.287.5225 • Fax 303.287.3873 • www.dcb1.com



HPE
HUTCHINSON-PAPESH
ENGINEERING CORPORATION
CONSULTING ELECTRICAL ENGINEERS
13906 W. BOWLES AVE. STE 102
LITTLETON, COLORADO 80127
V. 303.973.9229 F. 303.973.9255

A NEW BUILDING FOR:
GARAGECONDOS at RACINE CIR.
SMALL BUSINESS SOLUTIONS
BUILDING D

Design Project No. 19-907

Drawing Title

**GROUND LEVEL
POWER PLANS**

Drawing No.

E2.0D