

GENERAL SHEET NOTES

- 1 ALL GUEST ROOM RECEPTACLES SHALL BE TAMPER RESISTANT.
- 2 PROVIDE PUTTY PACKS AROUND BOXES IN PARTY WALLS.
- 3 VERIFY PTAC OUTLET LOCATIONS WITH EQUIPMENT SHOP DRAWINGS.
- 4 ALL HORNS IN GUEST ROOMS SHALL BE LOW-FREQUENCY TYPE.
- 5 PROVIDE GUEST MANAGEMENT ROOM SYSTEM FOR ALL ROOMS. SEE DRAWINGS FROM MARRIOTT FOR REQUIREMENTS AND PROVIDE ALL PARTS AND WIRING AND SYSTEMS AND PROGRAMMING SHOWN IN THESE

○ SHEET KEYNOTES

1 PROVIDE HALF SWITCHED RECEPTACLE (HUBBELL BR20C1WHI OR EQUAL BY LEVITON OR PASS & SEYMOUR). BASIS OF DESIGN FOR ROOM LIGHTING AND RECEPTACLE CONTROL SHALL BE NLIGHT NPP16DEFPSA POWER PACK FOR ROOM LIGHTING AND NLIGHT NPP20PL POWER PACK CONTROLLED BY LOW VOLTAGE CEILING SENSOR NLIGHT NCMPDT9RJB. ROOM SWITCH SHALL BE NLIGHT NPODMADXWH. OTHER MANUFACTURERS (i.e. WATTSTOPPER OR OTHERS) MAY BE USED IF THEY CAN MEET THIS SAME FUNCTIONALITY. WHEN ENTERING ROOM, THE CONTROLLED PORTION OF THE RECEPTACLE WILL TURN ON. LIGHTING WILL BE MANUAL ON AND EITHER MANUAL OR AUTO OFF.

- 2 COORDINATE MOUNTING HEIGHT OF TV WITH OWNER PRIOR TO ROUGHING IN
- 3 PROVIDE ALPHA RCC2505CF COMMAND CENTER STATION. LOCATE POWER SUPPLY ALPHA PWR2410A ADJACENT TO COMMAND CENTER STATION OR IN

RICHARDSON DESGN PARTNERSHIP, L.L.C. 510 South 600 East



THE GRAPHIC MATERIAL AND DESIGN ON THIS SHEET ARE INSTRUMENTS OF SERVICE AND REMAIN AT ALL TIMES THE PROPERTY OF THE RICHARDSON DESIGN PARTHESSHIP, LLC. REPRODUCTION OR REUSE OF THE MATERIAL AND DESIGN CONTAINED HEREN IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF THE RICHARDSON DESIGN PARTHESHIP, LLC.

© 2020 THE RICHARDSON DESIGN PARTNERSHIP, LLC. ALL RIGHTS DESERVENT.

SPECTRUM ENGINEERS 324 S. State St., Suite 400 Salt Lake City, UT 84111 800-678-7077

801-328-5151 fax: 801-328-5155 www.spectrum-engineers.com

CONSULTANT:

REV. DATE

ENLARGED METING & BOH POWER PLAN E401

PERMIT SET