



Addendum #1

To: Interested Vendors

From: Amy Sasina & Drew Youngstrom – Plante Moran

Date: 12/15/25

Re: Farmington Public Schools Structured Cabling RFP

Below are clarifications and answers to vendor questions to date:

1. The following changes were made to the Device Inventory in Appendix A:
 - a. Added video surveillance drops to all buildings. Note that these are not finalized and the quantity / locations are estimated. Final counts and locations will be confirmed on pre-installation walkthrough.
 - b. Clarification around relocated Relocated IDF's & Associated Cabling (added red and green notes).
 - c. Deleted video surveillance from Relocated IDF's & Associated Cabling (running all new).
2. Appendix C – Page 38 has added notation for Relocated IDFs

QUESTION	ANSWER
1. Do prevailing wages apply?	No, the bond was approved prior to prevailing wage law, therefore, prevailing wages do not apply.
2. Do you prefer 24 or 48 port patch panels?	Please use 24 port keystone patch panels. The district prefers two 24 port patch panels to be used rather than a single 48 port for their cabinet layout. In the case of a closet with very few drops, a single 24 port patch panel can be used.
3. Is the wireless cabling being demoed and recabled?	No, it is staying as is unless the IDF is moved.
4. Is the AV cabling being demoed and recabled?	No, it is staying as is unless the IDF is moved.

QUESTION	ANSWER
5. Is the video surveillance cabling being demoed and recabled?	Yes, it is getting demoed and recabled. Some of the locations may change. This is in the process of being finalized, but vendors should use the locations noted on the prints for estimated locations. Locations will be finalized and viewed as part of a preinstall walkthrough with awarded vendor.
6. Is everything getting recabled under Add / Alternate 1 for CAT6A?	Yes, see counts in device inventory.

- End of Addendum #1 -