

GENERAL: THESE ELECTRICAL DRAWINGS ARE DIAGRAMMATIC AND REQUIRE TRADESMAN SKILLED IN THE COMMERCIAL ELECTRICAL INDUSTRY TO COORDINATE THE NECESSARY INSTALLATIONS WITH OTHER TRADES. PROVIDE THE NECESSARY MATERIALS AND METHODS FOR THESE INSTALLATIONS; ADDITIONAL BLOCKING FOR CORRECT LIGHTING OUTLET AND DEVICE LOCATIONS, ETC. AT NO ADDITIONAL COST.

PROVIDE: ALL SERVICE CONDUITS FOR TELEPHONE SERVICE AND VERIFY LOCATION OF UTILITY PEDESTAL / MANHOLE WITH LOCAL UTILITY REP. PROVIDE INSTALLATIONS PER SERVICE PROVIDER'S REQUIREMENTS.

VERIFY ALL EXISTING SITE AND PROJECT CONDITIONS. UTILITY COMPANY SERVICES AND PROVIDE INSTALLATIONS IN COMPLIANCE WITH THESE CONDITIONS. FIELD VERIFY ALL CONDITIONS AND MAKE ALLOWANCES FOR THESE CONDITIONS IN FINAL PRICING. ANY DISCREPANCIES SHALL BE REPORTED TO THE ENGINEER TO RESOLUTION PRIOR TO FINAL PRICING.

PROVIDE ALL NECESSARY INSTALLATION PLANNING, MATERIALS AND LABOR TO ENSURE A COMPLETE AND OPERABLE SYSTEM FOR EACH SYSTEM DESIGN INDICATED ON THE DRAWINGS AND THESE CONDITIONS. ENSURE ALL WORK IS IN COMPLIANCE WITH THE CURRENT LOCAL AND NATIONAL ELECTRICAL CODES, FIRE AND SAFETY CODES. FURNISH TO THE G.C. ALL REQUIRED INSPECTION CERTIFICATES. THE CONTRACTOR IS RESPONSIBLE FOR ALL PERMITS, FEES, ETC. AND SHALL ENFORCE WORKERS IDENTIFICATION PER LOCAL AND STATE LAWS.

ALL WORK SHALL BE PERFORMED IN A NEAT AND WORKSMANSHIP LIKE MANNER, USING NEW MATERIALS WITH A ONE-YEAR WARRANTY MINIMUM. VERIFY FINISHES OF DEVICES, COVER PLATES, TRIMS, ETC. VERIFY APPROVED ROUTING OF SURFACE CONDUITS WHERE APPLICABLE.

THIS CONTRACTOR IS RESPONSIBLE FOR ACTUAL DISTANCES FOR FEEDERS AND CIRCUIT ROUTES. DO NOT USE THE FAULT CURRENT CALCULATION FOR ORDERING OR BIDDING FEEDERS. CONTRACTOR IS RESPONSIBLE FOR FIXTURE CORDS. DO NOT USE THE COMECHOCK FOR BIDDING OR ORDERING LIGHTING FIXTURES.

MATERIALS AND METHODS:

ALL ELECTRICAL EQUIPMENT, DEVICES, LIGHT FIXTURES, CONTROLS, ETC. SHALL BE INSTALLED WITH MANUFACTURER'S REQUIREMENTS AND INSTRUCTIONS. ENSURE WORKING CLEARANCES FOR GEAR AND PANELS AND ACCESS TO CONNECTIONS OFF ALL TERMINATIONS.

BRANCH CIRCUITRY AND GROUNDING SHALL COMPLY WITH CODES FOR LOCATION, USE AND SPECIAL OCCUPANCIES. CONDUITS AND FITTINGS SHALL BE AS REQUIRED AND ALLOWED FOR EACH LOCATION.

COORDINATE WITH THE ARCHITECT AND ALL TRADES FOR INTENDED AND ACTUAL LOCATIONS OF EQUIPMENT, CEILING LAYOUTS AND MATERIALS, STRUCTURAL AND MECHANICAL EQUIPMENT AND DUCTS PRIOR TO ROUGH-IN AND ORDERING OF EQUIPMENT OR LIGHTING FIXTURES.

SUBMITTALS:

SUBMIT COMPLETE SHOP DRAWINGS OF ALL DISTRIBUTION GEAR, PANEL, BOARDS AND LOAD CENTERS, FUSE TYPES AND BREAKERS WHERE SERIES RATING IS REQUIRED AND INDICATED ON THE DRAWINGS. CONTRACTOR TO CHECK AND CORRECT THE SUPPLIER'S SHOP DRAWINGS PRIOR TO SUBMITTING TO ENGINEER.

DISTRIBUTION GEAR AND PANELS:

PROVIDE A COMPLETE SERVICE DISTRIBUTION SYSTEM PER THE ONE LINE DIAGRAM. ENSURE CODE CLEARANCES, CONCRETE PADS, PROTECTION AND APPROVED LOCATIONS IN EQUIPMENT ROOMS. FUSES AND BREAKERS NOTED FOR SERIES RATING SHALL BE INSTALLED AS SPECIFIED TO ENSURE PROPER BREAKER BRACING PER THE LOCAL CURRENT CALCS. CONTRACTOR IS RESPONSIBLE FOR ADDITIONAL ENGINEERING DUE TO SUBSTITUTIONS OF WIRE TYPES THAT AFFECT I²TCALCS AND SERIES RATED STUDIES. ALL GEAR SHALL BE LABELED WITH PLAQUES AND PANEL INDICES TYPED WITH ACCURATE LOCUS IDENTIFIED.

PROVIDE FUSED AND NON-FUSED (WHERE APPROVED) DISCONNECT SWITCHES, RATED FOR LOCATION AND USE FOR ALL MECHANICAL AND SPECIAL EQUIPMENT.

PROVIDE SERVICE GROUNDING PER THE CURRENT N.E.C. ARTICLE 250. COORDINATE THE UPPER GROUNDING INSTALLATION PRIOR TO FOUNDATION POOL. ALL FEEDERS AND BRANCH CIRCUITS SHALL BE EQUIPPED WITH GROUNDING CONDUCTORS AND GROUNDING PER NEC 250. ENSURE GROUNDING JUMPERS AND BONING THROUGHOUT THE SYSTEM.

ELECTRICAL DEVICES:

ALL DEVICES SHALL BE RATED FOR THE OVER CURRENT AND PROTECTIVE DEVICE TYPE WITH ARCHITECT'S USE TO ORDERING. I²TCALCS. ENSURE GROUND FAULT DEVICES PER CODE AND ENSURE W.P. DEVICES ON EXTERIOR WALLS AND ON ROOF. ALL DEVICES SHALL BE RATED FOR USE IN SPECIAL OCCUPANCY USE AND LOCATIONS.

MECHANICAL EQUIPMENT:

REFERS TO MECHANICAL AND PUMPING DRAWINGS FOR EQUIPMENT LOCATIONS, EQUIPMENT SCHEDULE AND COORDINATE VOLTAGES AND NAMEPLATE OVER CURRENT PROTECTION. VERIFY UNITS FURNISHED WITH CONDUITS, STARTERS, ETC. ENSURE WIRE AND FUSE / BREAKER SIZES FOR UNITS. PROVIDE MAINTENANCE RECEPTACLES WHERE REQUIRED. ENSURE LIGHT, SWITCH AND GFI OUTLET IN ATTIC SPACES, DRAWL SPACES FOR MAINTENANCE.

FIRE ALARM AND DETECTION:

FIRE ALARM SYSTEM AND DETECTION IS CONSIDERED AS DESIGN-BUILD WITH THE CONTRACTOR'S SELECTED EQUIPMENT SUPPLIER. PROVIDE SHOP DRAWINGS AND COORDINATE WITH THE LOCAL CODE OFFICIALS FOR THE BUILDING TYPE AND OCCUPANCY FOR THE REQUIRED SYSTEM RULING. WHERE A NEW SYSTEM IS REQUIRED, PROVIDE DEDICATED POWER SUPPLY AND PHONE LINE CONDUIT TO THE TELEPHONE BOARD.

2. REFER TO THE ARCHITECTURAL PLANS FOR ADDITIONAL WORK AND CLARIFICATIONS.
3. ALL POWER AND LIGHTING DEVICE LOCATIONS AND CONTROLS ARE AS PER THE ARCHITECTURAL DRAWINGS. ENSURE THAT ALL LOCATIONS AND HEIGHTS ARE AS PER NEC AND ADA REQUIREMENTS. ALL OCCUPANCY SHALL BE AS PER NEC.
4. ENSURE ALL MATERIALS AND METHODS OF CONSTRUCTION TO COMPLY WITH CURRENT NEC (2017), I.B.C., NFPA, I.E.C. AND LOCAL ADOPTED OR AMENDED CODES.
5. COORDINATE WITH UTILITY COMPANY FOR FINAL TRANSFORMER SIZE, VOLTAGE, AND LOCATION. ANY DISCREPANCIES IN UTILITY TRANSFORMER SIZING AND/OR LOCATION SHALL BE REPORTED TO ENGINEER FOR REVISED/FINAL CURRENT CALCULATIONS AND POSSIBLE RE-SPECIFICATION OF EQUIPMENT ACING TYPES.
6. SUBMIT ELECTRICAL PLANS TO UTILITY COMPANY REPRESENTATIVE FOR FINAL REVIEW AND COORDINATION PRIOR TO WORK.
7. COORDINATE METERING INSTALLATION AND REQUIREMENTS WITH UTILITY COMPANY PRIOR TO WORK.
8. FIRE ALARM AND DETECTION DESIGN IS EXCLUDED. SUBMIT DRAWINGS TO FIRE PREVENTION CODE OFFICIALS FOR REVIEW AND SIGN OFF DETERMINATION FOR THIS CONSTRUCTION AND CONDITIONS, IF REQUIRED. E.C. TO SUBMIT FIRE ALARM DETECTION AND NOTIFICATION SYSTEM DESIGN IN THE FORM OF SUPPLIER SHOP DRAWINGS FOR FIRE ALARM SEPARATE PERMIT.
9. CONTRACTOR SHALL COORDINATE DIRECTLY WITH LOW VOLTAGE CONSULTANT (TELEPHONE, DATA, CABLE, RUMBLE ALARM, ETC.) FOR SPECIFIC REQUIREMENTS FOR EACH RESPECTIVE SYSTEM. ANY EMERGENCY RAMPAGES REQUIRED BY THESE SYSTEMS SHALL BE COORDINATED DIRECTLY WITH THE CONSULTANT / SUPPLIER. ANY ADDITIONAL LINE WORK REQUIRED FOR THESE SYSTEMS SHALL BE REPORTED TO THE ARCHITECTS AND SHALL BE REPORTED AND COORDINATED WITH ELECTRICAL ENGINEER.
10. ELECTRICAL CONTRACTOR SHALL UPSIZE ALL 120V BRANCH CIRCUITS EXCEEDING 75 LINEAR FEET OF RUN LENGTH TO 1/2" CLO TO ACCOMMODATE VOLTAGE DROP.

①	JUNCTION BOX
\$	SINGLE POLE SWITCH
\$	THREE WAY SWITCH
\$ _{OS}	WALL-BOX OCCUPANCY SENSOR
⊕	DUPLEX RECEPTACLE MIN. STD. WALL HEIGHT
⊕	4-PLEX RECEPTACLE MIN. STD. WALL HEIGHT
⊕	SPECIAL PURPOSE RECEPTACLE
<	TELECOMM. DATA OUTLET W/ 34" C. STUB-UP (CONDUIT, BOX AND MUDRING BY S/C)
≡	T.V. COAX OUTLET PRE-WIRED BY SERVICE PROVIDER
○	MOTOR
□	DISCONNECT-RATED FOR USE
WP	WEATHERPROOF
GF	GROUND FAULT INTERRUPTER, PROTECT DOWNSTREAM
AC	ABOVE COUNTER
HOR	MOUNT RECEPTACLE HORIZONTALLY.


PANEL "UNIT"	
208 / 120 VOLTS, 1 PHASE, 3 WIRE	
125 AMP/3 MLO	
NEW, SURFACE	
AC, 22, 000 OR SERIES	

HUTCHINSON PAPER ENGINEERING CORPORATION	
CONSULTING ELECTRICAL ENGINEERS	
V. 303.973.9779 F. 303.973.9759	

NOTES: MAX 125A THIS PANEL									
CIRCUIT DESCRIPTION	V A	CIRCUIT BKR	PHASE A B	CIRCUIT BKR	V A	CIRCUIT DESCRIPTION	V A	CIRCUIT DESCRIPTION	
1 LOWER LEVEL RECEP.TS	1080	20	GFI O	20	1042	LIGHTING / CLG.FAN	1		2
8 LOWER LEVEL RECEP.TS	1080	20	GFI O	20	696	GARAGE DOOR	4		3
5 MEZZANINE RECEP.TS	1080	20	GFI O	30/2	17500	"FEW"	6		4
2 SPECIAL RCPT (W/O CU)	2000	30	GFI O	7	1500	2 (W/O CU)HS	8		5
9 SPARE	20	20	O	60/2	5000	UNIT HEATER	10		10
11 SPARE	20	20	O	17000	(HG. CU)	12			12
13 SPARE	20	0	-		SPACE	14			14
15 SPACE	-	0	-		SPACE	16			16
17 SPACE	-	0	-		SPACE	18			18
19 SPACE	-	0	-		SPACE	20			20
21 SPACE	-	0	-		SPACE	22			22
23 SPACE	-	0	-		SPACE	24			24
PHASE A 9552.0					PHASE B 10526.0				

	CONV. KVA	DEMAND %	DEMAND KVA
LIGHTING	2.1	25	
RECEPTACLES < 10 KVA	4.2	100	4.2
RECEPTACLES > 10 KVA	0.0	50	0.0
LARGEST MOTOR	0.7	125	0.9
MOTORS	0.0	100	0.0
HEAT	13.5	100	13.5
MISCELLANEOUS 2	0.0	100	0.0
MISCELLANEOUS 3	0.0	100	0.0
MISCELLANEOUS 4	0.0	100	0.0
TOTAL KVA:	21.2		
		TOTAL AMPS:	101.8

600A "MS-C" SERVICE LOAD CALC		
LOAD DESIGNATION		LOAD (AMPS)
UNIT PANELS (21.2 KVA X 8)	=	169.6 KVA
HOUSE PANEL	=	9.5 KVA
SUB TOTAL =		179.1 KVA
	=	497.7 AMPS
		@208V, 3PH



LEGEND:

- SPECIAL PURPOSE RECEPTACLE
- TELECOMM / DATA OUTLET W/ 3/4" C. STUB-UP (CONDUIT, BOX AND WIRING BY E.C.)
- T.V. COAX OUTLET PRE-WIRED BY SERVICE PROVIDER
- MOTOR
- DISCONNECT-RATED FOR USE
- WEATHERPROOF
- GROUND FAULT INTERRUPTER, PROTECT DOWNSTREAM
- AC ABOVE COUNTER
- HOR MOUNT RECEPTACLE HORIZONTALLY.

DESIGN NOTES:

- DESIGN IS EXCLUDED. SUBMIT DRAWINGS TO FIRE FOR REVIEW AND SYSTEM DETERMINATION FOR THIS NS. IF REQUIRED, E.C. TO SUBMIT FIRE ALARM
- SYSTEM DESIGN IN THE FORM OF SUPPLIER SHOP PARATE PERMIT.
- DATE DIRECTLY WITH LOW VOLTAGE CONSULTANT (TELE. FOR REVIEW AND SYSTEM DETERMINATION FOR EACH PARTY RACWAYS REQUIRED BY THESE SYSTEMS SHALL BE THE CONSULTANT / SUPPLIER. ANY ADDITIONAL LINE NOT SHOWN ON THESE DRAWINGS SHALL BE WITH ELECTRICAL ENGINEER.
- ALL UPSIZE ALL 120V BRANCH CIRCUITS EXCEEDING 75 0/10 CU TO ACCOMMODATE VOLTAGE DROP.

CALLOUTS:

- SEE BLDG D NOTES RE: MONUMENT SIGN POWER
- SHOW ROUTING OF PVC CONDUITS TO BLDG D ON SITE PLAN

EQUIPMENT SPECIFICATIONS:

- TYPICAL WALL MOUNTED, LED LIGHT, (120V, 38W). REFER TO APPROVED PHOTOMETRIC FOR SPECIFICATION AND MOUNTING HEIGHT.
- TYPICAL POLE MOUNTED, LED LIGHT, (120V, 38W). REFER TO APPROVED PHOTOMETRIC FOR SPECIFICATION, POLE BASE DETAIL AND MOUNTING HEIGHT.
- HC-6 (#10 CU) TIMECLOCK
- HC-1 (#10 CU) TIMECLOCK
- SIGN WP.

STREETS: S. RACINE CIRCLE, E. PEAKVIEW AVE.

BUILDINGS: BUILDING "A", BUILDING "B", BUILDING "C", BUILDING "D"

OTHER FEATURES: ELECTRICAL SERVICE ENTRANCE (RE: ONE LINE DIAGRAM), APPROXIMATE LOCATION OF NEW UTILITY CO PAD-MOUNTED TRANSFORMER (RE: ONE LINE DIAGRAM)

 BUILDING "C" SITE ELECTRICAL PLAN
SCALE: 1"=40'-0"



SCALE: 1/8"=1'-0"



SCALE: 1/8"=1'-0'



GARAGECONDOS at RACINE CIR.
A NEW BUILDING FOR:
SMALL BUSINESS SOLUTIONS
BUILDING C
6507 S. RACINE CIRCLE, CENTENNIAL CO 80111

GROUND LEVEL, MEZZ. LIGHTING PLANS

E3.0C

